
SMART diagnostics IOT HUB (SD-HUB-1)

The SMARTdiagnostics ® IoT HUB is the next generation of full asset health solutions designed by KCF Technologies to handle the most complex asset monitoring needs, including triggered collections, multi-functional sensor ports and the ability to withstand higher temperatures with external power sourcing, including an optional wired power solution.

- Multiple power options available
- Capable of triggered and simultaneous collections
- •Compatible with multiple sensor types, including third party options











HIGH TEMPERATURE

Power is supplied to the IoT HUB, which can be positioned away from extreme environments. This allows sensors to be placed on high temperature machines without compromising battery power or temperature limits.

TRIGGERED MACHINES

In triggered machines, such as robots, the IoT HUB can be configured to activate sensors in response to unique movement patterns. This allows for more focused data collection as opposed to continuous monitoring.

SHIELDED MACHINES

Assets in shielded areas, such as those covered by metal or screening, pose an issue where wireless sensors struggle to connect to the network. The IoT HUB provides a wired solution for monitoring these machines.





Learn more at kcftech.com/hardware

| Mechanical | | Mechanical | |
|--|--|---------------------------|--|
| Weight | 672g (with Battery Power Module), | Weight | 100g |
| vv cigire | 621g (with AC Power) | Enclosure Material | Radel R5800 and 303 Stainless Steel |
| Enclosure Material | Radel R5800 | Mounting | Magnetic or Hard Mount, #10 or M5 Socket |
| Mounting | Magnetic or Hard Mount, #10 or M5 Socket Head | | Head |
| Max. Mounting Bolt Torque | 15 in·lb [1.7 N·m] | Max. Mounting Bolt Torque | 30 in·lb [3.4 N·m] |
| Environmental | | Environmental | |
| Storage Temperature | -40°C to 125°C (-40°F to 257°F) | Storage Temperature | -40°C to 125°C (-40°F to 257°F) |
| Min. Operating Temp. | -40°C (-40°F) | Min. Operating Temp. | -40°C (-40°F) |
| Max. Operating Temp. | 85°C (185°F) | Max. Operating Temp. | 125°C (257°F) |
| P Rating | IP67 | IP Rating | IP69 |
| lazardous Certification | Class I, Division 2 (planned) | Hazardous Certification | Class I, Division 2 (planned) |
| Wireless Radio | | Power | |
| Radio | KCF DART™ Wireless 2.4GHz ISM band | Power Source Options | 3.3VDC, provided by the HUB |
| Antenna | Internal dipole antenna | Power Consumption | {TBD} μA (standby) {TBD} mA (active) |
| CC ID | Z5IHB1 | Inputs | |
| С | 24664-HB1 | Collection Mode | Timed Interval Triggered |
| Power | | Input Types | 24VDC power (optional) |
| Power Source Options | 3.6 VDC Lithium Thionyl Chloride (battery module) | | 0-24 VDC edge trigger (optional) 7 Sensor Ports |
| | 120-240 VAC (AC power module) | Sensor Input Types | KCF Vibration Sensor |
| attery Life | External 24 VDC Wired via 4-pin M12 Male Port {TBD} | Acceleration | |
| Inputs | | Range | +/- 19 g typical, +/- 16 g nominal |
| Collection Mode | Interval | Resolution | 0.866 mg nominal |
| nput Types | Triggered 0-24 VDC edge trigger (optional) | Noise Floor | 1.496 mg RMS @64 Hz / 13.01 mg RMS @ 8192 Hz |
| input Types | 7 Sensor Ports (caps available for unused ports) | Transverse Sensitivity | 10% typical |
| Sensor Input Types | KCF Wired Vibration Sensor | Frequency Response | +/- 5% 0-2700 Hz +/- 3% 2700-4000 Hz |
| SD-DH-1-MB (w/ magnets and battery) SD-DH-1-MA (w/ magnets and AC module) | | Samples per Acquisition | 4096 |
| | | Spectral Lines | 2048 |
| | | Anti-Aliasing Filter | 4000 Hz low-pass cut-off, 3 rd order Sallen-k |
| | | Sampling Frequency | 64 Hz – 8192 Hz configurable |
| | | Temperature Sensor | |
| | SD-DH-1-M | Range | -40°C to 125°C (-40°F to 257°F) |
| | furt assessed as associated | | |

FCC STATEMENT

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. This equipment complies with the FCC RF radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with a minimum distance of 20cm between the radiator and any part of your body. Changes or modifications not expressly approved by KCF Technologies could void the user's authority to operate the equipment.

INDUSTRY CANADA STATEMENT

The term IC before the Certification/Registration number only signifies that the Industry Canada technical specifications were met. This device complies with Industry Canada's license-exempt RSSs Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference including interference that may cause undesired operation of the device.

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes : (1) l'appareil ne doit pas produire de brouillage, et (2) l'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.

This equipment complies with the IC RF radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with a minimum distance of 20cm between the radiator and any part of your body.

